



Ref. Certif. No.

FR_700138/M1

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Fixed socket-outlet

Name and address of the applicant

LEGRAND FRANCE
128 AVENUE DU MARECHAL DE LATTRE DE TASSIGNY
87045 LIMOGES CEDEX
FRANCE

Name and address of the manufacturer

LEGRAND COLOMBIA S.A.
Calle 65A#93 91 Alamos Zona Industrial
11001 BOGOTA D.C.
COLOMBIA

Name and address of the factory

LEGRAND COLOMBIA S.A.
Calle 65A#93 91 Alamos Zona Industrial
11001 BOGOTA D.C.
COLOMBIA


Note: When more than one factory, please report on page 2

Additional Information on page 2

Ratings and principal characteristics

See Annex

Trademark / Brand (if any)



Customer's Testing Facility (CTF) Stage used

/

Model / Type Ref.

DOMINO SENCIA
References : See Annex

Additional information (if necessary may also be reported on page 2)

Supersedes CBTC FR_700138 dated 31/01/2017. Addition of product references

Additional Information on page 2

A sample of the product was tested and found to be in conformity with

IEC 60884-1:2002(ed.3) +A1:2006 +A2:2013

As shown in the Test Report Ref. No. which forms part of this Certificate

158657-730383


This CB Test Certificate is issued by the National Certification Body



LCIE – Laboratoire Central des Industries Electriques
33, avenue du Général Leclerc – BP8
FR 92 266 Fontenay aux Roses Cedex
www.lcie.fr



LABORATOIRE CENTRAL DES
INDUSTRIES ELECTRIQUES
S.A.S au capital de 15.745.984 €
RCS Nanterre B 408 363 174
33 avenue du Général Leclerc
F - 92266 FONTENAY AUX ROSES

Signature: 
Julien Gauthier
Certification Officer

Date: 22/10/2019

ANNEX

References, ratings and main characteristics:

| References | Pattern | Rated values |
|------------|-----------|-------------------------|
| AP1128 | 2 P+E | 15 A 127 V~ |
| AP1228 | 2 x 2 P+E | 15 A 127 V~ |
| AP5231 | 1 + 2 P+E | 15 AX 127 V~15 A 127 V~ |
| AP5328 | 6 + 2 P+E | 15AX 127V~ + 15A 127V~ |

| Classification | |
|---|-----------------------|
| Standard sheet | 1 et 1A (IEC 60906-2) |
| Degree of protection | IP20 |
| Provision for earthing | with earthing contact |
| Method of connecting the cable | rewirable |
| Type of terminals | screw type |
| Socket-outlets | |
| Number of socket-outlets | see above table |
| Degree of protection against electric shock | normal protection |
| Existence of shutters | without |
| Method of application - mounting | flush-type |
| Method of installation | design A |



LCIE – Laboratoire Central des Industries Electriques
33, avenue du Général Leclerc – BP8
FR 92 266 Fontenay aux Roses Cedex
www.lcie.fr

Date: 22/10/2019



LABORATOIRE CENTRAL DES
INDUSTRIES ELECTRIQUES
S.A.S au capital de 15.745.984 €
RCS Nanterre B 408 363 174
33 avenue du Général Leclerc
F - 92266 FONTENAY AUX ROSES

Signature: 
Julien Gauthier
Certification Officer