

CERTIFICATE OF COMPLIANCE

Certificate Number 20191108-E146159
Report Reference E146159-19991217
Issue Date 2019-NOVEMBER-08

Issued to: PASS & SEYMOUR INC
50 Boyd Ave
Syracuse, NY 13209 USA

This certificate confirms that representative samples of Attachment Plugs, Fuseless
(See Addendum for Additional Information.)

Have been investigated by UL in accordance with the Standard(s) indicated on this Certificate.

Standard(s) for Safety: ANSI/UL 498, Attachment Plugs and Receptacles.
CSA-C22.2 No. 42, General Use Receptacles, Attachment Plugs, and Similar Wiring Devices.

Additional Information: See the UL Online Certifications Directory at <https://iq.ulprospector.com> for additional information.

This *Certificate of Compliance* does not provide authorization to apply the UL Mark. Only the UL Follow-Up Services Procedure provides authorization to apply the UL Mark.

Only those products bearing the UL Mark should be considered as being UL Certified and covered under UL's Follow-Up Services.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>



CERTIFICATE OF COMPLIANCE

Certificate Number 20191108-E146159
Report Reference E146159-19991217
Issue Date 2019-NOVEMBER-08

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

Addendum –

Products Covered:

USL/CNL Angle Attachment Plugs, Cat. Nos. 3861, 3867 and 3869.

General:


The devices covered by this Report are Angle Plugs which are intended for use in accordance with the National Electric Code.

Cat. No. 3861 is an attachment plug having blades arranged to cooperate with a 3-pole, 3-wire grounding type receptacle rated 30 A, 125/250 V, packaged in an individual carton containing an extra blade which is intended as a substitute for the “L” shaped blade in which case the blade arrangement would permit use with a 50 A, 125/250 V, 3-pole, 3-wire nongrounding type receptacle.

Cat. No 3867 is an attachment plug having blades arranged to cooperate with a 3-pole, 4 wire receptacle rated 30 A, 125/250 V packaged in an individual carton containing an extra blade which is intended as a substitute for one of the wide blades in which case the blade arrangement would permit use with a 50 A, 250 V, 3-pole, 4-wire, grounding-type receptacle.

Cat. No. 3869 is an attachment plug having blades arranged to cooperate with a 2-pole, 3-wire receptacle rated 30 A, 250 V packaged in an individual carton containing an extra blade which is intended as a substitute for one of the wide blades in which case the blade arrangement would permit use with a 50 A, 250 V, 2-pole, 3-wire, grounding-type receptacle.

Each individual carton includes instructions indicating the proper methods of blade assembly.



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

